

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated: 17/06/2025

No.

It is certified that an inspection team headed by **Abhishek Pandey (Assistant Engineer)** (Name of Officers with designation) from U.P. Jal Nigam (Rural) PHED Inspected the **Awadh Girls Inter Collage Kadja Semariyawan, Sant Kabir Nagar** (Name & Address of the school) on **16/06/2025** (date of inspection) and on the basis of water test report (Attached) bearing no **SKN/June/06** dated **17/06/2025** of District Water Testing Lab (NABL) U.P.Jal Nigam Rural Sant Kabir Nagar (PHED Lab) certified that the **Awadh Girls Inter Collage Kadja Semariyawan, Sant Kabir Nagar Nagar** (Name of School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

This certificate is valid till: 17/06/2026

Signature with Seal:

Name : Shri Mahendar Ram

Designation : Executive Engineer

Name & Add.of the Office/Department :UP Jal Nigam

To

The Manager

Awadh Girls Inter Collage

Kadja Semariyawan, Sant Kabir Nagar

(Name & Address of the Institution)

Executive Engineer
Divisional Office
U.P. Jal Nigam (Rural)
Sant Kabir Nagar

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies



Test Report

TC-12263

District Level Water Analysis Laboratory, U.P. Jal Nigam, (Rural) Sant Kabir Nagar

Address- Office of Executive Engineer, Construction division, U.P Jal Nigam, Near Over Bridge Industrial Area, Khalilabad, Sant Kabir Nagar, 272175

Certificate No.: TC-12263.

Report No:	SKN/June/06	Issue Date:	19/06/2025		
Remark				Page No	1-2
	Arpan	Address:	UPJN Sant Kabir Nagar	Mob:	9918803036

Customer Details

Name and contact info. of customer	Awaadh Girls Inter Collage, 9621001048
Office Name and Address	Kadja Semariyawan, Sant Kabir Nagar
Ref Letter No & Date	16/06/2025

Basic details of sample

District	Sant Kabir Nagar	Block	Semariyawan
Gram Panchayat	-	Village	-
Habitation	-	Location	Kadja Semariyawan, Sant Kabir Nagar
Water Source	HP,	Sample No.	SKN/06
Quantity of Sample	1 liter	Date of Collection	16/06/2025
Receiving Date	16/06/2025	S. Collector	Jamal Ahmad
Sample Depositor	Jamal Ahmad	Sampling Method	
Analysis Start Date	17/06/2025	Analysis Completion Date:	18/06/2025

Technical Data of Analysis

	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH* @ 25°C	7.49	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2017 (Electrometric method)
2	Turbidity NTU	3.16	1	5	IS 3025 (Pt 10):2017
3	TDS mg/L	316	500	2000	IS 3025 (Pt 16):2017

4	Fluoride mg/L	0.32	1	1.5	APHA 23 rd Edition 4500-F Method C (Electrode method) 2017
5	Total Hardness mg/L	288	200	600	IS 3025 (Part 21):2019
6	Total Alkalinity mg/L	238	200	600	IS 3025 (Part 23):2019
7	Chloride mg/L	66.8	250	1000	IS 3025 (Part 32):2019
8	Iron mg/L	0.16	1	1	APHA 23 rd Edition 3500-Fe Method B (Phenanthroline Method) 2017
9	Sulphate mg/L	13.9	200	400	APHA 23 rd Edition 4500-SO4 Method E (Turbidity Method) 2017
10	Nitrate mg/L	Below Detection Limit	45	45	APHA 23 rd Edition 4500 NO3-Method D (UV Screening Method) 2017
11	Calcium mg/L	49.8	75	200	IS 3025 (Part 40):2019
12	Magnesium mg/L	39.38	30	100	IS 3025 (Part 46):2019
13	Color (CU) at pH	5	5	15	APHA 23 rd Edition Color 2120 B (Visual Comparison Method)

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 10 days (in case of non-perishable items only) from the date of issue of tests reports.
5. * Mark Parameter is not NABL scope.

Prepared By-

(Arpan)

Technical Manager
District Level Water Analysis Laboratory
Sant Kabir Nagar UP, IN

Authorized Signatory:

(Arpan)

Testing Lab In charge

Laboratory Contact details

Technical Manager
District Level Water Analysis Laboratory
Sant Kabir Nagar UP, IN

Email- arpannishad224168@gmail.com

Mob-9918803036

x.....End of Report.....x



उत्तर प्रदेश जल निगम(ग्रामीण)

कार्यालय : अधिशासी अभियन्ता, खण्ड कार्यालय, उ०प्र० जल निगम(ग्रामीण)
औद्योगिक क्षेत्र, खलीलाबाद, जिला : संत कबीर नगर (उ० प्र०)

E-mail I.D:- cdsantkabirnagar@gmail.com

पत्रांक

641

1 W-08 / 50

दिनांक: 21 / 06 / 2025

अवध गर्ल्स इण्टर कालेज
कडजा सेमरियावां
संत कबीर नगर।

विषय:- जल परीक्षण रिपोर्ट के सम्बन्ध में।

उपरोक्त विषयक आपके पत्र दिनांक 16/06/2025 के सन्दर्भ में आप द्वारा उपलब्ध कराये गये जल नमूनों का परीक्षण रिपोर्ट तैयार कर लिया गया है। परीक्षण शुल्क का बीजक आशय से प्रेषित हैं, कि बीजक का भुगतान कर परीक्षण रिपोर्ट प्राप्त करना सुनिश्चित करें।

1. विभाग द्वारा उपलब्ध कराये जा रहे प्रमाण पत्र आप के द्वारा प्रेषित सैम्पल/ पेयजल स्रोत के लिए ही मान्य है।
2. आप द्वारा यह सुनिश्चित किया जाये कि पेयजल स्रोत के आसपास एवं भण्डारण टैंक की समय समय पर सफाई की जाए।

भवदीय

mt

(महेन्द्र राम)
अधिशासी अभियन्ता